



Bristol Training Facility
 2912 River Road
 Croydon, PA 19021

Doylestown Training Facility
 1760 S. Easton Road
 Doylestown, PA 18901

Local Level (State) Training Office
 275 Swamp Road, Farmhouse 2nd Fl
 Newtown, PA 18940

Certification & Degree Office
 275 Swamp Road, Cottage 1
 Newtown, PA 18940

SCBA Inspection Checklist

Equipment assigned to: _____ Inspected by: _____

Inspection date: _____ Inspector's signature: _____

SCBA Serial #: _____ Date: _____

Cylinder DOT #: _____ Hydro Date: _____

Inspection Procedures	PASS	FAIL
Cylinder:		
1. Check for damage		
2. Current hydrostatic test date		
3. Operational check of the cylinder		
4. Ensure cylinder is full		
Harness & Backpack:		
5. Inspect all straps for damage		
6. Inspect backpack for damage		
7. Inspect all hoses for damage		
8. Operational check of straps and buckles		
SCBA Functional Inspection		
9. Operational check of face piece * (Mask must not show signs of excess heat exposure)		
10. Operational check of regulator and face piece		
11. Operational check of the emergency bypass valve		
12. Operational check of the low pressure warning device		
13. Activates PASS device if part of SCBA unit		
All inspection criteria are in accordance with NFPA 1001, 2013 edition.		

By signing below the person who inspected the SCBA unit, as well as, the Chief or delegated Officer is confirming that this inspection was done and all information is correct. Only SCBA Units that pass this inspection should be used for live fire training. Instructors will have the right to inspect any unit on the day of live fire training, if they feel the SCBA unit being used does not meet this inspection requirement.

All students should be familiar with the SCBA unit they are using for the Live Fire Training as well as having been Fit Tested to the size mask they are to use.

Review by Instructors Signature:

 Print Signature Date

